

NSF International

789 N. Dixboro Road, Ann Arbor, MI 48105 USA

RECOGNIZES

Periodic Global Limited

Hong Kong

AS COMPLYING WITH NSF/ANSI 42, 53, 401 AND ALL APPLICABLE
REQUIREMENTS.

PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE
AUTHORIZED TO BEAR THE NSF MARK.



This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in NSF's Official Listings for the referenced standards. For the most current and complete Listing information, please access NSF's website (www.nsf.org).

A handwritten signature in black ink, appearing to read "David Purkiss", is written over a horizontal line.

December 5, 2022
Certificate# C0731888 - 01

David Purkiss
Vice President, Global Water Division

NSF International

789 N. Dixboro Road, Ann Arbor, MI 48105 USA

RECOGNIZES

Puridic Global Limited

Facility: # 1 Republic of Korea

AS COMPLYING WITH NSF/ANSI 42, 53, 401 AND ALL APPLICABLE
REQUIREMENTS.

PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE
AUTHORIZED TO BEAR THE NSF MARK.



This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in NSF's Official Listings for the referenced standards. For the most current and complete Listing information, please access NSF's website (www.nsf.org).

A handwritten signature in black ink, appearing to read "David Purkiss", is written over a horizontal line.

December 5, 2022
Certificate# C0731899 - 01

David Purkiss
Vice President, Global Water Division

Test Report

No. HKES230300003167_2

Date : Jun 2, 2023

Page 1 of 3

CIRCLE HOME LIMITED
 D40, 17/F, BLOCK D, WAH LOK INDUSTRIAL BUILDING, 31-35 SHA MEI ST., FO TAN, ST, NT

This report supersedes all previous documents bearing the test report HKES230300003167 with amendment of sample description as requested by client.

Report on laboratory testing of the submitted samples identified by the client as Drinking Water.

1. Sample Identification

<u>Sample No. Assigned by SGS</u>	<u>Sampling Description as Reported by Client</u>	<u>Date of Commencing Sampling as Reported by Client</u>
W23031312	PF-10	Mar 20, 2023
W23031313	CS-17HF	Mar 20, 2023
W23031314	PL-15	Mar 20, 2023

Sampling by : Client
 Sample Delivery by : SGS
 Sample Receiving Date and Condition : Mar 20, 2023 under refrigerated condition
 Testing Period : Mar 20, 2023 – Mar 27, 2023

2. Test Method and Testing Results

Please refer to the following page(s).

Signed for and on behalf of
 SGS Hong Kong Ltd.



Chan Mei Wah Amy
 Chemist

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

H34078099

2. Test Method and Testing Results (Cont'd)

Parameter	Reference Method	W23031312	Quality Water Supply Scheme for Buildings – Fresh Water (Plus)
pH Value at 25°C	APHA 23 rd ed. 4500 H ⁺ B	8.0	6.5 - 9.2 pH Unit
Color (Pt-Co Color Unit)	APHA 23 rd ed. 2120 B	< 1 at pH 8.0	≤ 15 TCU
Turbidity (NTU)	APHA 23 rd ed. 2130 B	< 0.50	≤ 3.0 NTU
Conductivity at 25°C (µmhos/cm)	APHA 23 rd ed. 2510 B	200	≤ 300 µS/cm
Total Recoverable Iron (mg/L)	In House Method ENV-M-002 (ICP-OES)	< 0.05	≤ 0.3 mg/L
<i>E. coli</i> (CFU/100mL)	DoE (1994) Section 7.5 & 7.7	0*	0 CFU/100mL
Total Coliform (CFU/100mL)		0*	0 CFU/100mL
Total Recoverable Lead (µg/L)	In House Method ENV-M-001 (ICP-MS)	< 0.5	≤ 10 µg/L
Total Recoverable Cadmium (µg/L)		< 0.5	≤ 3 µg/L
Total Recoverable Chromium (µg/L)		< 0.5	≤ 50 µg/L
Total Recoverable Nickel (µg/L)		< 5.0	≤ 70 µg/L

Parameter	Reference Method	W23031313	Quality Water Supply Scheme for Buildings – Fresh Water (Plus)
pH Value at 25°C	APHA 23 rd ed. 4500 H ⁺ B	9.2	6.5 - 9.2 pH Unit
Color (Pt-Co Color Unit)	APHA 23 rd ed. 2120 B	< 1 at pH 9.2	≤ 15 TCU
Turbidity (NTU)	APHA 23 rd ed. 2130 B	< 0.50	≤ 3.0 NTU
Conductivity at 25°C (µmhos/cm)	APHA 23 rd ed. 2510 B	200	≤ 300 µS/cm
Total Recoverable Iron (mg/L)	In House Method ENV-M-002 (ICP-OES)	< 0.05	≤ 0.3 mg/L
<i>E. coli</i> (CFU/100mL)	DoE (1994) Section 7.5 & 7.7	0*	0 CFU/100mL
Total Coliform (CFU/100mL)		0*	0 CFU/100mL
Total Recoverable Lead (µg/L)	In House Method ENV-M-001 (ICP-MS)	< 0.5	≤ 10 µg/L
Total Recoverable Cadmium (µg/L)		< 0.5	≤ 3 µg/L
Total Recoverable Chromium (µg/L)		< 0.5	≤ 50 µg/L
Total Recoverable Nickel (µg/L)		< 5.0	≤ 70 µg/L

(to be continued)

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

H34078100

2. Test Method and Testing Results (Cont'd)

Parameter	Reference Method	W23031314	Quality Water Supply Scheme for Buildings – Fresh Water (Plus)
pH Value at 25°C	APHA 23 rd ed. 4500 H ⁺ B	9.1	6.5 - 9.2 pH Unit
Color (Pt-Co Color Unit)	APHA 23 rd ed. 2120 B	< 1 at pH 9.1	≤ 15 TCU
Turbidity (NTU)	APHA 23 rd ed. 2130 B	< 0.50	≤ 3.0 NTU
Conductivity at 25°C (µmhos/cm)	APHA 23 rd ed. 2510 B	170	≤ 300 µS/cm
Total Recoverable Iron (mg/L)	In House Method ENV-M-002 (ICP-OES)	< 0.05	≤ 0.3 mg/L
E. coli (CFU/100mL)	DoE (1994) Section 7.5 & 7.7	0*	0 CFU/100mL
Total Coliform (CFU/100mL)		0*	0 CFU/100mL
Total Recoverable Lead (µg/L)	In House Method ENV-M-001 (ICP-MS)	< 0.5	≤ 10 µg/L
Total Recoverable Cadmium (µg/L)		< 0.5	≤ 3 µg/L
Total Recoverable Chromium (µg/L)		< 0.5	≤ 50 µg/L
Total Recoverable Nickel (µg/L)		< 5.0	≤ 70 µg/L

* "0" = Negative, no *E. Coli* / Total Coliform were found in 100mL of sample

*** End of Report ***

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

H34078101